

Aircon Optimum Performance

For Optimum Performance

General - During Cleaning

- Close all windows and doors.
- Draw the curtains / blinds.
- Human comfort temperature is between 23°C - 25°C.
- It takes an average of 1 - 2 hours to cool a room.
- Do not block air inlets and outlets of the indoor unit and outdoor unit.



AIR FILTER

- Air filters should be cleaned every two weeks.
- Failure to do so will impair the flow and cooling capacity of your system.

AIR PURIFYING FILTERS

- Helps remove fine dust, pollen, tobacco smoke and odour in the room.
- Air purifying filters need to be replaced every three months.
- Replace when colour turns dark even if filters are not three months old.

Note: Once the air purifying filter elements get dirty, it is not reusable and must be thrown away.

GENERAL SERVICING

- To achieve better air conditioning performance, periodical maintenance by a qualified service technician is recommended, apart from regular cleaning by the user.
- Frequent usage of the air conditioning system as well as the environmental factors result in air conditioners turning dirty and dusty.
- To improve the condition of the system and to prolong its life span, please contact our service shop for maintenance.



PROSYN@HOME LTD
22 Willow Street
LONDON
EC2A 4BH
Tel 0845 644 2351
Fax 0845 128 3961